



February, 26, 2018

City of Pecos / PWS ID 1950001 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the Ground water system during 6/2011. This monitoring is required by Texas Commission on Environmental Quality's Drinking Water Standard's and Federal "Safe Drinking water Act." Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if water is free indicator bacteria. Following a positive routine Total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we required to notify you of this violation.

If you have any questions regarding this violation, you may contact Gary Rumbaugh at 432-445-2421